

# VOC Content Test Certificate

Tuesday February 26<sup>th</sup>, 2008

Manufacturer: RLA Polymers Pty Ltd

215 Colchester Road

Kilsyth Victoria 3137

Sample Description: RL1017 Polyurethane Adhesive

Date Tested: February 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia</b>  <b>Green Star Office Design IEQ-13 v2</b>  <b>Green Star Office Interiors IEQ-11 v1.1</b>	<b>RL1017</b>
Timber Flooring Adhesive 100 grams per Litre as VOC content material	<b>6 grams per Litre as VOC                  content per material</b>



Dr. Vyt Garnys  
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
 ACA, AIRAH, FMA  
 Managing Director and Principal Consultant

F0802-20